

Warringtonfire Mid-East Listing No. 029 & 041 Certificate of Factory Production Control

Producer: ComTuer
Product: Timber Fire Doors
Factory Location: Heibronn, Germany
Date of Inspection: 11th April 2006

This Document Certifies that:

The Factory Production Control (FPC) procedures/routines operated by ComTuer at the above address have been subject to FPC Inspection and found to comply with the FPC requirements of the Warringtonfire Mid-East Listing Scheme subject to implementation of agreed measures, including sampling of products. Labels will be applied to unmodified products by ComTuer.

This certificate is valid for a period of 5 years from date of issue provided that a routine surveillance visit is carried out annually to check ongoing implementation of and compliance with the FPC assessed as acceptable.

Note:

This certificate will become invalid if the manufacturer makes significant changes to the assessed as acceptable FPC system, (such as sub-contracting part of the manufacturing process which was previously all carried out in house or new production methods are implemented).

This certificate will become invalid if the manufacturer moves the manufacture of the product from the factory location identified above.

Products Covered by this Certificate are:

ComTuer Timber Fire Doors (Listing Nos. 029 & 041)

Signed:



R J Williams
Certification Manager

Issue Date: 8th May 2006
Revised: 24th August 2006
Valid to: 7th May 2011

CERTIFICATE OF APPROVAL
No. ME0041

This is to certify that the referenced product of

Comtuer Zentrale Weimann GmbH

Wannenaeckerstr. 73, 74078 Heilbronn, Germany
Tel: + 49-7131-262225 Fax: + 49-7131-262220

has been assessed against the requirements of the *warringtonfire - mideast certification scheme* and is approved for use within the scope of the test and/or assessment report(s) referenced.

Comtuer Zentrale Weimann GmbH 'COMFIRE BS-30' Doorsets

**30 Minutes Integrity & insulation Performance In Accordance With
BS 476: Part 22: 1987**

Test And Assessment Report Reference	Valid Until
WF Report No. 156870	Until 1 st August 2011

COMFIRE BS-30 DOORSETS	
Construction	Timber based leaves and frames
Maximum leaf dimensions	2810 mm high and 1278 mm wide subject to a maximum area of 2.99 m ²
Configuration	Single-acting, single-leaf, latched

Certification is awarded on the basis of initial type testing to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by warringtonfire. The currency of the certification may be verified at www.warringtonfire.net/mideast.

Signed and sealed for and on behalf of Warrington Certification



Kenneth J Knight
Chairman - Management Council
Page 1 of 1

Issued: 24th August 2006
Valid to: 23rd August 2011

CERTIFICATE OF APPROVAL
No. ME0029

This is to certify that the referenced product of

Comtuer Zentrale Weimann GmbH

Wannenaeckerstr. 73, 74078 Heilbronn, Germany
Tel: + 49-7131-262225 Fax: + 49-7131-262220

has been assessed against the requirements of the *warringtonfire - mideast certification scheme* and is approved for use within the scope of the test and/or assessment report(s) referenced.

Comtuer Zentrale Weimann GmbH 'COMFIRE BS-60' Doorsets


**60 Minutes Integrity & insulation Performance In Accordance With
BS 476: Part 22: 1987**

Test And Assessment Report Reference	Valid Until
WF Report No. 154155 Issue 3	Until 1 st May 2011
WF Report No. 156869	Until 1 st August 2011

COMFIRE BS-60 DOORSETS	
Construction	Timber based leaves and frames
Maximum leaf dimensions	2530 mm high and 1041 mm wide subject to a maximum area of 2.45 m ²
Configuration	Single-acting, single-leaf, latched
Optional glazing dimensions (max)	576 mm high and 165 mm wide, subject to a maximum area of 0.88 m ²

Certification is awarded on the basis of initial type testing to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by warringtonfire. The currency of the certification may be verified at www.warringtonfire.net/mideast.

Signed and sealed for and on behalf of Warrington Certification



Kenneth J Knight
Chairman - Management Council

Issued: 8th May 2006
Revised: 24th August 2006
Valid to: 7th May 2011